

**TABLE C1**  
**CONCRETE AIR CONTENT PRICE ADJUSTMENTS**

<u>Air Content Range</u>			<u>% Payment of Unit Price</u>
<u>Minimum</u>		<u>Maximum</u>	
1.1*	and	below	0%
0.6	to	1.0*	50%
0.1	to	0.5*	75%
Low air	tolerance	limit	100%
	Target		100%
High air	tolerance	limit	100%
0.1	to	0.5*	95%
0.6	to	1.0*	85%
1.1	to	1.5*	75%
1.6	to	2.0*	60%
2.1*	and	above	0%

\* Air content deviation above or below the acceptable limits

**TABLE C2**  
**WATER CEMENT RATIO PRICE ADJUSTMENTS**

<u>Water Cement Ration Range*</u>			<u>% Payment of Unit Price</u>
<u>Minimum</u>		<u>Maximum</u>	
0.051	and	above	0%
0.031	to	0.050	50%
0.021	to	0.030	70%
0.011	to	0.020	80%
0.001	to	0.010	90%
-----	Limit	-----	

\* W/C deviation above the acceptable limits

**TABLE C3**  
**VIBRATOR FREQUENCY PRICE ADJUSTMENTS**

<u>Vibrator Frequency</u>			<u>% Payment of Unit Price</u>
<u>Minimum</u>		<u>Maximum</u>	
below 3500			90%
3500	to	4999*	95%
5000	to	8000	100%
8001	to	9000	90%
9001	to	10,000	75%
above 10,000			50%

\* Engineer may extend the lower specification limit to include this range

**Note:** Penalty shall apply to area half the distance to the adjacent vibrator or edge of slab and the length traveled during the non-compliance

**TABLE C4**  
**CERTIFIED PLANT INSPECTION PRICE ADJUSTMENTS**

<u>Type of Work</u>	<u>Daily Penalty</u>
Structural Concrete & Patching	\$ 500
Paving	\$1,000

**Note:** Penalty for failure to provide certified plant inspection.  
Partial days may be assessed

**TABLE C5**  
**LATE CURING APPLICATION PRICE ADJUSTMENTS**

<u>Time After Finishing (hrs)</u>			<u>% Payment of Unit Price</u>
½	to	<1	90%
1	to	<1½	80%
1½	to	<2	65%
2	to	<3	50%
More	than	3	0%